

CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**
2. **Certificate No:** FM19CA0008X
3. **Equipment:** EXP-1 and EXP-2 Probe Intelligent Controller
(Type Reference and Name)
4. **Name of Listing Company:** INOV8 Systems Ltd
5. **Address of Listing Company:** Unit 6 Edgewater Road Office Park
Belfast, BT3 9JQ United Kingdom
6. The examination and test results are recorded in confidential report number:

PR446508 dated 22nd March 2019
7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CSA-C22.2 No. 0.4:2017, CSA-C22.2 No. 0.5:2016, CSA-C22.2 No. 30:2020,
CSA-C22.2 No. 94.2:2015, CAN/CSA-C22.2 No. 61010-1:2012, CSA-C22.2 No. 60529:2016
8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
10. **Equipment Ratings:**

Explosionproof for Class I, Division 1, Groups C and D hazardous locations. The ambient temperature rating is -20°C to +60°C, Temperature Class T4...T3, with indoors and outdoors ratings Type 4 and IP66.

Certificate issued by:



J.E. Marquedant
VP, Manager - Electrical Systems

27 September 2022

Date

To verify the availability of the Approved product, please refer to www.approvalguide.com

THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: information@fmapprovals.com www.fmapprovals.com